

LICENCE

No. 20547

Issued to:

Applicant:

AB Plast s.r.l. - Hager Group

Via del Artigianato n°6

25080 MAZZANO (BS)

Italy

Licensee:

AB Plast s.r.l. - Hager Group

Via del Artigianato n°6

25080 MAZZANO (BS)

Italy



Product : socket-outlets (2-pole)
 Trade name(s) : HAGER
 Type(s)/model(s) : French Socket - Gallery Series (see appendix)

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 1447

SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 08/11/2017

ir. C. Lana,
 Certification Manager

© Only integral publication of this certificate, including the annex, is allowed

This certificate is only valid combined with the publication on the following web address: www.sgs.com/ee



SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

| | | |
|-----------------------|---|--|
| Product | : | socket-outlets (2-pole) |
| Trade name(s) | : | HAGER |
| Type(s)/Model(s) | : | French Socket - Gallery Series (see appendix) |
| rated voltage (Un) | : | 250 Vac |
| rated current (In) | : | 16 A |
| terminals | : | screwless, rigid and flexible |
| earthing | : | with and without earthing pin |
| design | : | design A rewirable |
| standard sheet | : | V of NBN C 61-112-1 I of NF C-61-314 IIIa of NF C 61-314 |
| existence of shutters | : | with shutters |
| degree of protection | : | IP 20 |
| method of mounting | : | flush type |
| markings | : | are shown on the body |

Additional information

See Appendix

TESTS

Test requirements

NBN C 61-112-1 based on IEC 60884-1:2002 + A1:2006 + A2:2013

Test results

The test results are laid down in certification file ref.628432/01

Remarks

This certificate is based on test report ref.628432.01

Conclusion

The examination proved that all test requirements were met.

Checked by, project leader : Luigi Zanutto - 08/11/2017

Department Manager,
Product Certification :

Certification Manager :



Zanutto 2017-11-08

FACTORY LOCATION(S)

Berker Polska Sp.z.o.o
Ul. Sredzka 19
62-035 KORNIK
Poland

| Technical code | Description | Rated current (A) | Rated Voltage (V) | Frequency (Hz) | Type of terminal | IP |
|----------------|---|-------------------|-------------------|----------------|------------------|------|
| WXF100 | French socket 2P+T screwless | 16A | 250V | 50 | Screwless | IP20 |
| WXF102 | French socket 2P screwless | 16A | 250V | 50 | Screwless | IP20 |
| WXF105 | French socket refurbishing 2P+T screwless | 16A | 250V | 50 | Screwless | IP20 |
| WXA450 | Gallery frame 2M (NF mark) | NA | NA | NA | NA | NA |

0 1 2 3 4 5

