

CERTIFICATE

Issued to:
Applicant:
Hager Electro SAS
132 Boulevard d'Europe
67210 Obernai, France

Licensee:
Hager Electro SAS
132 Boulevard d'Europe
67210 Obernai, France

Product : Isolating switches
Trade name(s) : HAGER
Type(s)/model(s) : SB....

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60669-2-4:2005
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900186

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 4 July 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-104407

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



Kreny Lin
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Isolating switches
Trade name(s)	: HAGER
Type(s)/model(s)	: SB.....
Rated voltage	: 230 Vac, 400 Vac
Rated current	: 16 A, 25 A, 32 A, 40 A, 63 A
Pattern no.	: 1, 2, 3, 03
Number of poles	: 1, 2, 3, 4
Degree of protection	: IP4X with enclosure and IP2X without enclosure
Method of mounting	: flush type, top hat rail, according to EN50022
Terminals	: cage-type screw terminals
Applied types with signallamps	: pattern 1 and 2 ; maximum rating 32 A

TESTS**Test requirements**

EN 60669-2-4:2005

Test result

The test results are laid down in DEKRA test file 222305800.

Additional information

This certificate replaces certificate No. 2187538.01 which we herewith declare invalid.

Conclusion

The examination proved that all requirements were met.

Factory location

Hager Polo Produkcja Sp. zo.o.
Ul. Fabryczna 10
43-100 Tychy, Poland

Nomenclature breakdown:

For example: SBN263N

SB: Modular load break disconnect switch

N: Toggle color / light indicator

N: grey toggle

R: red toggle

T: light indicator, connection on top

B: light indicator, connection on bottom

2: Number of poles

1: 1 pole

2: 2 poles

3: 3 poles

4: 4 poles

63: rated current

16: 16 A

25: 25 A

26: 25 A in frame size up (based on 40-63 A frame size)

32: 32 A

33: 32 A in frame size up (based on 40-63 A frame size)

40: 40 A

63: 63 A

N: Special Market

blanc: All countries

N: India range