

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Rocker switches
Name and address of the applicant	AB Plast s.r.l. - Hager Group Via del Artigianato n° 6 25080 MAZZANO (BS) Italy
Name and address of the manufacturer	AB Plast s.r.l. - Hager Group Via del Artigianato n° 6 25080 MAZZANO (BS) Italy
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Berker Polska Sp.z.o.o Ul. Sredzka 19 62-035 KORNIK Poland
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	250 Vac, 16 AX, pattern no. 2, rocker, screwless (rigid and flexible) terminals design A, rewirable, for trunking, IP20, certification mark complies with the requirements, markings are shown on the body
Trademark (if any)	HAGER
Customer's Testing Facility (CTF) Stage used	CTF Stage 2
Model / Type Ref.	Series Gallery (see appendix)
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 Switch intended to be used in the trunking systems : 45-trunking GBD, GBA & TA-C Trunkings cover adaptors LF, BRx Skirting SL 45-Pole DA & DB Desk module Easybloc
A sample of the product was tested and found to be in conformity with	IEC 60669-1:1998, IEC 60669-1:1998/AMD1:1999, IEC 60669-1:1998/AMD2:2006
As shown in the Test Report Ref. No. which forms part of this Certificate	630005.01

This CB Test Certificate is issued by the National Certification Body

SGS Belgium N.V. - Division SGS-CEBEC  
Business Riverside Park, Avenue Internationale laan 55 Build. D, BE-1070 BRUSSEL,  
Belgium

SGS



Technical code	Pattern no.	Description	Rated current	Rated Voltage	Freq (Hz)	Type of terminal	IP
WXF436B	2	2 Poles switch white	16AX	250V	50	Screwless	IP20
WXF436T	2	2 Poles switch alu	16AX	250V	50	Screwless	IP20
WXF436N	2	2 Poles switch Black	16AX	250V	50	Screwless	IP20

0 1 2 3 4 5

