

UKCA DECLARATION OF CONFORMITY No. UKCA 22.3193.06.22

We Hager Electro SAS
BP3
67215 OBERNAI CEDEX - FRANCE

Declare that the product(s)
Designation

Switch disconnecter H1000

Type reference(s)

HCE800H, HCE800U, HCE801H, HCE801U, HCE970H, HCE970U,
HCE971H, HCE971U

Trademark

Hager

is (are) in conformity with the relevant United Kingdom legislation:

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)
 - SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)
 - SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)
-
-

Standard(s) and/or relevant document(s) to which conformity is declared

Standard number + relevant amendments together with the edition dates

BS EN 60947-3: 2021-02

BS EN IEC 63000:2018

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of Hager Electro SAS - BP3 - 67215 OBERNAI CEDEX - FRANCE

Name of signatory

Mr Eric Boivin

Function of signatory

Certification Manager

Place and date of issue

Obernai, 21th June 2022

Signature



UKCA DECLARATION OF CONFORMITY

No. UKCA 22.3193.06.22

Type references

Product Reference	Product Description
HCE800H	Switch disconnecter H1000 3P 800A
HCE800U	Switch disconnecter H1000 3P 800A
HCE801H	Switch disconnecter H1000 4P 800A
HCE801U	Switch disconnecter H1000 4P 800A
HCE970H	Switch disconnecter H1000 3P 1000A
HCE970U	Switch disconnecter H1000 3P 1000A
HCE971H	Switch disconnecter H1000 4P 1000A
HCE971U	Switch disconnecter H1000 4P 1000A

UKCA DECLARATION OF CONFORMITY

No. UKCA 22.3193.06.22

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

Evidences approved by: Site:	Engineering Quality / Certification Obernai
Only designated standards published on GOV.UK (https://www.gov.uk/guidance/designated-standards) are used:	Yes
Scope and classification fully covers the product (case 1 of Hager Group risk analysis):	Yes
Comments :	
Hager Group risk analysis: (Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document DMS034433 - Hager Group risk analysis)	Not applicable
Certificate(s) / test report(s):	KRC 5917-2b KRC 15235b
Mark approval(s):	No mark approvals
Product documentation :	See Hager website
Comments:	Product conforms to EN standard and no deviation between BS EN standard and EN standard exists