

UKCA DECLARATION OF CONFORMITY No. 22.3248.06.22

We Hager Electro SAS
BP3
67215 OBERNAI CEDEX - FRANCE

Declare that the product(s)

Designation

Switch disconnecter H630

Type reference(s)

HCD400H_HCD400U_HCD630H_HCD630U_HCD401H_HCD401U_
HCD631H_HCD631U

Trademark

Hager

is (are) in conformity with the relevant United Kingdom legislation:

- SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)
- SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)
- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)

.....

.....

Standard(s) and/or relevant document(s) to which conformity is declared

Standard number + relevant amendments together with the edition dates

BS EN 60947-3: 2021-02
BS EN IEC 63000: 2018-12

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of Hager Electro SAS

Name of signatory

Mr Eric Boivin

Function of signatory

Certification manager

Place and date of issue

Obernai, 21th June 2022

Signature



UKCA DECLARATION OF CONFORMITY

No. 22.3248.06.22

Type references

Type reference	Description
HCD400H	Switch disconnecter H630 3P 400A
HCD400U	Switch disconnecter H630 3P 400A
HCD630H	Switch disconnecter H630 3P 400A
HCD630U	Switch disconnecter H630 3P 400A
HCD401H	Switch disconnecter H630 4P 400A
HCD401U	Switch disconnecter H630 4P 400A
HCD631H	Switch disconnecter H630 4P 400A
HCD631U	Switch disconnecter H630 4P 400A

UKCA DECLARATION OF CONFORMITY

No. 22.3248.06.22

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

Evidences approved by: Site:	Engineering Quality / Certification Obernai
Only designated standards published on GOV.UK (https://www.gov.uk/guidance/designated-standards) are used: Scope and classification fully covers the product (case 1 of Hager Group risk analysis): Comments :	Yes Yes
Hager Group risk analysis: (Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document DMS034433 - Hager Group risk analysis)	Not applicable
Certificate(s) / test report(s):	KRC 5917-2b KRC 15235b
Mark approval(s):	No mark approvals
Product documentation :	See Hager website
Comments:	No deviation between EN 60947-3 and BS EN 60947-3