

We Hager LTD
Hortonwood 50
TELFORD-TF1 7FT-UK

Declare that the product(s)

Designation

JKD2 Tri-Meter P&L TPN DBO Range 200A

Type reference(s)

JKD2 Range

Trademark

Hager

is (are) in conformity with the relevant United Kingdom legislation:

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)
- SI 2016/1153 Measuring Instruments Regulations 2016 (as amended)
- SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)
- SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)

.....

Standard(s) and/or relevant document(s) to which conformity is declared

Standard number + relevant amendments together with the edition dates

BS EN 61439-3: 2012 incorporating corrigenda September 2013, December 2015 and March 2019

BS EN IEC 63000:2018

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of Hager LTD

Name of signatory

Ian Ellis

Function of signatory

Certification Manager MDS

Place and date of issue

Telford, UK 23/03/2022

Signature

Ian Ellis

UKCA DECLARATION OF CONFORMITY

No. 22_3379_03_22

Type references

Product Reference	Product Description
JKD2884TM	Power/Lighting & Mechanical Board 8/8/4 Way Pan Assemblies Pulsed & Modbus

Product Reference	Product Description
JK01B	Single Pole Busbar Blank – 125A
JK222PK	Key Lock with One Key
JK2PLATEM	Spare Gland Plate Including Drill Marking – 1.2mm
JK201SPD	Type 1 & 2 Surge Protection Kit
JK202SPD	Type 2 Surge Protection Kit

UKCA DECLARATION OF CONFORMITY

No. 22_3379_03_22

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

Evidences approved by: Site:	Engineering Quality / Certification Telford
Only designated standards published on GOV.UK (https://www.gov.uk/guidance/designated-standards) are used: Scope and classification fully covers the product (case 1 of Hager Group risk analysis): Comments :	Yes BS EN 61439-3:2012 incorporating corrigenda September 2013, December 2015 and March 2019 Yes Designated After 2016 BS Standard updated in March 2019
Hager Group risk analysis: (Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document DMS034433 - Hager Group risk analysis)	DMS034433 followed using case 1 of Hager Group method: Designated Standard Used
Certificate(s) / test report(s):	G2126 JKD Tri-Meter P&L TPN DBO Range
Mark approval(s):	None
Product documentation :	See Hager Website User Instruction Leaflet ZD0902
Comments:	

UKCA DECLARATION OF CONFORMITY

No. 22_3379_03_22

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

Designated Standards

Designated standard UKCA Electrical Equipment (Safety) Regulations 2016:

S.I. 2016 No. 1101	EN 61439-3:2012	Low-voltage switchgear and controlgear assemblies – Part 3: Distribution boards intended to be operated by ordinary persons (DBO)	01/01/2021	0009/21
-----------------------	-----------------	---	------------	---------

Designated standard UKCA Electromagnetic Compatibility Regulations 2016:

S.I. 2016 No. 1091	EN 61439-3:2012	Low-voltage switchgear and controlgear assemblies – Part 3: Distribution boards intended to be operated by ordinary persons (DBO)	01/01/2021	0007/21
-----------------------	-----------------	---	------------	---------

Designated standard UKCA RoHS:

S.I. 2012 No. 3033	EN IEC 63000:2018	Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances	01/01/2021	0037/21
-----------------------	-------------------	--	------------	---------