

Declaration of performance

N°: **0333-CPR-292073**

- 1) Product family - appellation :
Radio smoke Detector LS – 10 years
- 2) Product reference :
S155-22X
- 3) Indented use:
Smoke detection for domestic application in accordance with EN 14604 (2005) +AC 2008
- 4) Name, registered trade name and contact address of the manufacturer:
Hager Security SAS – Rue du pré de l'Orme 38926 Crolles – France
- 5) System of assessment and verification of constancy of performance:
System 1
- 6) Name of the notified body which has delivered a certificate: **Afnor Certification**
Identification number of the notified body: **0333**
Certificate reference : **0333-CPR-292073**
- 7) Delivery of an European Technical assessment : **NA.**

8) Declared performance:

EN 14604 (2005) - Harmonized Technical specification - Essential Characteristics	Performance
§ 4.12 - Smoke alarm signals	Passed
§ 4.13 - Battery removal indication	Passed
§ 4.14 - Battery connections	Passed
§ 4.15 - Battery capacity	Passed
§ 4.16 - Protection against the ingress of foreign bodies	Passed
§ 4.17 - Additional requirements for software	Passed
§ 4.18 - Inter-connectable smoke alarms	Passed
§ 5.2 - Repeatability	Passed
§ 5.3 - Directional dependence	Passed
§ 5.4 - Initial sensitivity	Passed
§ 5.5 - Air movement	Passed
§ 5.6 - Dazzling	Passed
§ 5.7 - Dry heat	Passed
§ 5.8 - Cold	Passed
§ 5.9 - Damp heat 4 days	Passed
§ 5.10 - Corrosion SO2 4 days	Passed
§ 5.11 - Impact	Passed
§ 5.12 - Vibration (operational)	Passed
§ 5.13 - Vibration (endurance)	Passed
§ 5.14 - EMC	Passed
CEM - § 5.14 a) - Mains supply voltage dips and short interruptions	Not Applicable
CEM - § 5.14 b) - Electrostatic discharge	Pass
CEM - § 5.14 c) - Radiated electromagnetic fields 1-2GHz	Pass
CEM - § 5.14 e) - Fast transient burts	Not Applicable
CEM - § 5.14 f) - Sow high energy transients	Not Applicable
CEM: § 5.14 d), e) et f) - With Cable	Not Applicable
§ 5.15 - Fire sensitivity	Passed
§ 5.16 - Battery fault warning	Passed
§ 5.17 - Sound output	Passed
§ 5.18 - Sounder durability	Passed
§ 5.19 - Inter-connectable smoke alarms	Passed
§ 5.20 - Alarm silence facility	Passed
§ 5.21 - Variation in supply voltage	Passed
§ 5.22 - Battery reversal	Not Applicable
§ 5.23 - Standby power source	Not Applicable
§ 5.24 - Battery SAD electrical safety	Passed
Annexe L - Camping Cars requirements	Passed

NPD = no performance determined / NA = not applicable

9) The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Place and date of issue : **Crolles January 2014**

Signature :

Signer Name : **Jean Michel Bouchet**

Position : **Product Certification and Regulation Manager**

