

Declaration of performance

N°: DoP_hager_TG600Ay

1) Product family - appellation : **Stand alone smoke detectors**

2) Product references: TG600A: 5 years TG600AL: 10 years

3) Indented use or uses:

Smoke detection for domestic application in accordance with EN 14604: 2005 +AC 2008

4) Name, registered trade name and contact address of the manufacturer: Hager Security SAS – 140, Rue du pré de l'Horme 38926 Crolles – France

5) System or systems of assessment and verification of constancy of performance : System 1

6) Name of the notified body which has delivered a certificate: Kriwan

Identification number of the notified body: 1772
COP reference TG600A: 1772-CPR-140653
COP reference TG600AL: 1772-CPR-140365

7) Delivery of an European Technical assessment: NA.

8) Declared performance:

Harmonized Technical specification EN 14604 : 2005 and AC 2008- Essential Caracteristics	Performance
§ 4.12 - Smoke alarm signals	Passed
§ 4.13 - Battery removal indication	Passed
§ 4.14 - Battery connections	Passed
§ 4.15 - Battery capacity	Passed
§ 4.16 - Protection against the ingress of foreign bodies	Passed
§ 4.17 - Additional requirements for software	Passed
§ 4.18 - Inter-connectable smoke alarms	Passed
§ 5.2 - Repeatability	Passed
§ 5.3 - Directionnal dependence	Passed
§ 5.4 - Initial sensitivity	Passed
§ 5.5 - Air movement	Passed
§ 5.6 - Dazzling	Passed
§ 5.7 - Dry heat	Passed
§ 5.8 - Cold	Passed
§ 5.9 - Damp heat 4 days	Passed
§ 5.10 - Corosion SO2 4 days	Passed
§ 5.11 - Impact	Passed
§ 5.12 - Vibration (operational)	Passed
§ 5.13 - Vibration (endurance)	Passed
§ 5.14 -EMC	Passed
CEM - § 5.14 a) - Mains supply voltage dips and short interruptions	Not Applicable
CEM - § 5.14 b) - Electrostatic discharge	Passed
CEM - § 5.14 c) - Radiated electromagnetic fields 1-2GHz	Passed
CEM - § 5.14 e) - Fast transient burts	Not Applicable
CEM - § 5.14 f) -Sow high energy transcients	Not Applicable
CEM: § 5.14 d), e) et f) - With Cable	Not Applicable
§ 5.15 - Fire sensitivity	Passed
§ 5.16 - Battery fault warning	Passed
§ 5.17 - Sound output	Passed
§ 5.18 - Sounder durability	Passed
§ 5.19 - Inter-connectable smoke alarms	Not Applicable
§ 5.20 - Alarm silence facility	Passed
§ 5.21 - Variation in supply voltage	Passed
§ 5.22 - Battery reversal	Passed
§ 5.23 - Standby power source	Not Applicable
§ 5.24 - Battery SAD electrical safety	Passed
Annexe L - Camping Cars requirements	Passed

NPD = no performance determined / NA = not applicable

CBD003-a 6LE000028A 1/2



200

9) The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Place and date of issue: **Crolles February 2015** Signature :

Signer Name : Jean Michel Bouchet

Position: Product Certification and Régulation Manager

CBD003-a 6LE000028A 2/2