

UKCA DECLARATION OF CONFORMITY No. 22.3177.06.21

We Hager Electro SAS
BP3
67215 OBERNAI CEDEX - FRANCE

Declare that the product(s)

Designation

MCCB H400 TM

Type reference(s)

HHD250U_HHD400U_HND250U_HND400U_HND251U_HND401U_HHD30
0Z_HKD250U_HKD251U

Trademark

Hager

is (are) in conformity with the relevant United Kingdom legislation:

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)
- SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)
- SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)

.....

.....

Standard(s) and/or relevant document(s) to which conformity is declared

Standard number + relevant amendments together with the edition dates

BS EN 60947-2:2017-10+A1:2020-02

BS EN IEC 63000:2018

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of Hager Electro SAS

Name of signatory

Mr Eric Boivin

Function of signatory

Certification Manager

Place and date of issue

Obernai, 21th June 2022

Signature



UKCA DECLARATION OF CONFORMITY

No. 22.3177.06.21

Type references

Type reference	Description
HHD250U	MCCB H400 3 poles 250A Icu/Ics= 25/25 kA TM
HHD400U	MCCB H400 3 poles 400A Icu/Ics= 25/25 kA TM
HHD300Z	MCCB H400 3 poles 300A Icu/Ics= 25/25 kA TM
HND250U	MCCB H400 3 poles 250A Icu/Ics= 50/50 kA TM
HND400U	MCCB H400 3 poles 400A Icu/Ics= 50/50 kA TM
HND251U	MCCB H400 4 poles 250A Icu/Ics= 50/50 kA TM
HND401U	MCCB H400 4 poles 400A Icu/Ics= 50/50 kA TM
HKD250U	MCCB H400 3P 70kA 250A TM
HKD251U	MCCB H400 4P 70kA 250A TM

UKCA DECLARATION OF CONFORMITY

No. 22.3177.06.21

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

Evidences approved by: Site:	Engineering Quality / Certification Obernai
Only designated standards published on GOV.UK (https://www.gov.uk/guidance/designated-standards) are used: Scope and classification fully covers the product (case 1 of Hager Group risk analysis): Comments :	Yes Yes
Hager Group risk analysis: (Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document <u>DMS034433</u> - Hager Group risk analysis)	Risk analysis 22.1871.06.22
Certificate(s) / test report(s):	CB test certificate No. NL-64929 and Test report No. 2243599.62 Certificate No. KRC 5917-1c Supplier Compliance certificate KRC 15235
Mark approval(s):	No marks
Product documentation :	See Hager Website
Comments:	BS EN Standard requirements are identical to EN Standards