

UKCA DECLARATION OF CONFORMITY No. 22 3464 09 22

We Hager Electro SAS
BP3
67215 OBERNAI CEDEX - FRANCE

Declare that the product(s)

Designation

Add on Block

Type reference(s)

B Range

Trademark

Hager

is (are) in conformity with the relevant United Kingdom legislation:

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)
 - SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)
 - SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)
-
-

Standard(s) and/or relevant document(s) to which conformity is declared

Standard number + relevant amendments together with the edition dates

BS EN 61009-1:2012+A12:2016

EN 61009-1(2012)+A1+A2+A11+A12

BS EN IEC 63000:2018

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of Hager Electro SAS

Name of signatory

Eric Boivin

Function of signatory

Responsable Homologation / Approval Manager

Place and date of issue

Obernai, le 07/09/2022

Signature



UKCA DECLARATION OF CONFORMITY

No. 22_3464_09_22

Type references

| Product Reference | Product Description |
|-------------------|---|
| BDA263 | Earth leakage add-on block 2P 63A 30mA A Class |
| BDA363 | Earth leakage add-on block 3P 63A 30mA A Class |
| BDA463 | Earth leakage add-on block 4P 63A 30mA A Class |
| BEA263 | Earth leakage add-on block 2P 63A 100mA A Class |
| BEA363 | Earth leakage add-on block 3P 63A 100mA A Class |
| BEA463 | Earth leakage add-on block 4P 63A 100mA A Class |
| BFA263 | Earth leakage add-on block 2P 63A 300mA A Class |
| BFA363 | Earth leakage add-on block 3P 63A 300mA A Class |
| BFA463 | Earth leakage add-on block 4P 63A 300mA A Class |
| BNA263 | Earth leakage add-on block 2P 63A 100mA A S Class |
| BNA363 | Earth leakage add-on block 3P 63A 100mA A S Class |
| BNA463 | Earth leakage add-on block 4P 63A 100mA A S Class |
| BPA263 | Earth leakage add-on block 2P 63A 300mA A S Class |
| BPA363 | Earth leakage add-on block 3P 63A 300mA A S Class |
| BPA463 | Earth leakage add-on block 4P 63A 300mA A S Class |

UKCA DECLARATION OF CONFORMITY

No. 22_3464_09_22

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

| | |
|---|--|
| Evidences approved by: Site: | Engineering Quality / Certification Telford |
| Only designated standards published on GOV.UK (https://www.gov.uk/guidance/designated-standards) are used: Scope and classification fully covers the product (case 1 of Hager Group risk analysis): Comments : | Yes EN 61009-1(2012)+A1+A2+A11+A12 Yes Designated Before 2016 |
| Hager Group risk analysis: (Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document <u>DMS034433</u> - Hager Group risk analysis) | DMS034433 followed using case 1 of Hager Group method: Designated Standard Used |
| Certificate(s) / test report(s): | STR 2642 / IMQ |
| Mark approval(s): | IMQ |
| Product documentation : | See Hager Website |
| Comments: | None |

UKCA DECLARATION OF CONFORMITY

No. 22_3464_09_22

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

Designated Standards

Designated standard UKCA Electrical Equipment (Safety) Regulations 2016:

| | | | | |
|-----------------------|-----------------|--|------------|---------|
| S.I. 2016 No. 1101 | EN 61009-1:2012 | Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs) - Part 1: General rules | 01/01/2021 | 0009/21 |
|-----------------------|-----------------|--|------------|---------|

Designated standard UKCA Electromagnetic Compatibility Regulations 2016:

| | | | | |
|-----------------------|-----------------|--|------------|---------|
| S.I. 2016 No. 1091 | EN 61009-1:2012 | Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs) - Part 1: General rules | 01/01/2021 | 0007/21 |
|-----------------------|-----------------|--|------------|---------|

Designated standard UKCA RoHS:

| | | | | |
|-----------------------|-------------------|--|------------|---------|
| S.I. 2012 No. 3033 | EN IEC 63000:2018 | Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances | 01/01/2021 | 0037/21 |
|-----------------------|-------------------|--|------------|---------|