

UKCA DECLARATION OF CONFORMITY No.

We Hager LTD
Hortonwood 50
TELFORD-TF1 7FT-UK

Declare that the product(s)

Designation

Meter Box Switch (Insulated)

Type reference(s)

VC Range

Trademark

Hager

is (are) in conformity with the relevant United Kingdom legislation:

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)
 - SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)
 - SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)
-
-

Standard(s) and/or relevant document(s) to which conformity is declared

Standard number + relevant amendments together with the edition dates

BS EN 60947-3:2009+A2:2015 incorporating Corrigenda September 2012 and November 2013

BS EN IEC 63000:2018

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of Hager LTD - Hortonwood 50 - TELFORD-TF1 7FT-UK

Name of signatory

Mr Ian Ellis

Function of signatory

Certification Manager (Enclosure Systems)

Place and date of issue

Telford, UK 01/12/2022

Signature

Ian Ellis

UKCA DECLARATION OF CONFORMITY

No. UKCA 22.3054.12.22

Type references

VC Meter Box Range

| Meter Box Switch | Product Description |
|------------------|-----------------------|
| VC02SW | 100A Meter Box Switch |

UKCA DECLARATION OF CONFORMITY

No. UKCA 22.3054.12.22

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

| | |
|---|---|
| Evidences approved by: Site: | Engineering Quality / Certification Telford |
| Only designated standards published on GOV.UK (https://www.gov.uk/guidance/designated-standards) are used: Scope and classification fully covers the product (case 1 of Hager Group risk analysis): Comments : | Yes BS EN 60947-3:2009+A2:2015 Yes Designated Before 2016 |
| Hager Group risk analysis: (Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document DMS034433 - Hager Group risk analysis) | DMS034433 followed using case 1 of Hager Group method: Designated standard used |
| Certificate(s) / test report(s): | Hager UK Test Report G2206 Hager UK Test report G1892 Enclosed Domestic Meterbox Switch Hager UK General Test Report G1892A 100A Meterbox Switch Hager Group Short Circuit Test report No HOM 13274 Enclosed Meterbox Switch DEKRA Test Report 2143638.55 Switch Disconnecter DEKRA Test Report 2143638.56 Switch Disconnecter Hager Group Declaration of Conformity 19.1516.06.19 Routine Test program for Enclosed Meterbox Switch |
| Mark approval(s): | No |
| Product documentation : | Documentation supplied with Meter Box Range Instruction leaflet ZD0760 |
| Comments: | None |

UKCA DECLARATION OF CONFORMITY

No. UKCA 22.3054.12.22

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

Designated Standards

Designated standard UKCA Electrical Equipment (Safety) Regulations 2016:

| | | | | |
|-----------------------|-------------------------|---|------------|---------|
| S.I. 2016 No. 1101 | EN 60947-3:2009/A2:2015 | Low-voltage switchgear and controlgear - Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units | 01/01/2021 | 0009/21 |
|-----------------------|-------------------------|---|------------|---------|

Designated standard UKCA Electromagnetic Compatibility Regulations 2016:

| | | | | |
|-----------------------|-----------------|---|------------|---------|
| S.I. 2016 No. 1091 | EN 60947-3:2009 | Low-voltage switchgear and controlgear - Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units | 01/01/2021 | 0007/21 |
|-----------------------|-----------------|---|------------|---------|

Designated standard UKCA RoHS:

| | | | | |
|-----------------------|-------------------|--|------------|---------|
| S.I. 2012 No. 3033 | EN IEC 63000:2018 | Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances | 01/01/2021 | 0037/21 |
|-----------------------|-------------------|--|------------|---------|