

## UKCA DECLARATION OF CONFORMITY No. UKCA 22.3484.09.22

We **Hager Engineering LTD**  
**Hortonwood 50**  
**TELFORD-TF1 7FT-UK**

Declare that the product(s)  
Designation

**Hager Consumer Unit Range (outdoor)**  
**Type : Garage Board, Surface, IP55**

Type reference(s)

**VE24AH**

Trademark

Hager

is (are) in conformity with the relevant United Kingdom legislation:

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)
- SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)
- SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)

.....

.....

**Standard(s) and/or relevant document(s) to which conformity is declared**

*Standard number + relevant amendments together with the edition dates*

**BS EN 61439-3:2012 inc corr September 2013, December 2015 and March 2019**

**BS EN IEC 63000:2018**

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

**This declaration of conformity is issued under the sole responsibility of the manufacturer.**

**Signed for and on behalf of**

Mr Ian Ellis

**Function of signatory**

Certification Manager (Enclosure Systems)

**Place and date of issue**

Telford, UK 30/09/2022

**Signature**

*Ian Ellis*

## **UKCA DECLARATION OF CONFORMITY**

No. UKCA 22.3484.09.22

### **Evidence (s)**

*Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation*

<b>Garage Board Insulated</b>	<b>No. of outgoing circuits</b>	<b>Product Description</b>
VE24AH	2	IP55 Insulated Garage Board c/w 40A RCCB main device + 32A MCB + 6A MCB

## UKCA DECLARATION OF CONFORMITY

No. UKCA 22.3484.09.22

### Evidence (s)

*Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation*

Evidences approved by: Site:	Dave Kelly, UK Telford Certification MDS
Only designated standards published on GOV.UK ( <a href="https://www.gov.uk/guidance/designated-standards">https://www.gov.uk/guidance/designated-standards</a> ) are used:	Yes BS EN 61439-3:2012
Scope and classification fully covers the product (case 1 of Hager Group risk analysis):	Yes Designated after 2016
Comments :	
Hager Group risk analysis: (Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document <u>DMS034433</u> - Hager Group risk analysis)	DMS034433 followed using case 1 of Hager Group method:  Designated standard
Certificate(s) / test report(s):	G1357 Type Test Certificate Garage Units G1939-1 General test report Consumer units BS EN 61439-3 G2133 General test report for BS EN 61439-3 2019 corrigenda G2156 Certificate of Design Verification VE24AH Hager Group Short circuit Test report N° HOM 05612
Mark approval(s):	No
Product documentation :	Documentation supplied with Garage Board: ZD0630
Comments:	None

## UKCA DECLARATION OF CONFORMITY

No. UKCA 22.3484.09.22

### Evidence (s)

*Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation*

#### Designated Standards

Designated standard UKCA Electrical Equipment (Safety) Regulations 2016:

S.I. 2016 No. 1101	EN 61439-1:2011	Low-voltage switchgear and controlgear assemblies – Part 1: General rules	01/01/2021	0009/21
S.I. 2016 No. 1101	EN 61439-3:2012	Low-voltage switchgear and controlgear assemblies – Part 3: Distribution boards intended to be operated by ordinary persons (DBO)	01/01/2021	0009/21
S.I. 2016 No. 1101	EN 61439-3:2012, EN 61439- 3:2012/AC:2019-04	Low-voltage switchgear and controlgear assemblies – Part 3: Distribution boards intended to be operated by ordinary persons (DBO)	01/01/2021	0009/21

Designated standard UKCA Electromagnetic Compatibility Regulations 2016:

S.I. 2016 No. 1091	EN 61439-1:2011	Low-voltage switchgear and controlgear assemblies – Part 1: General rules	01/01/2021	0007/21
S.I. 2016 No. 1091	EN 61439-3:2012	Low-voltage switchgear and controlgear assemblies – Part 3: Distribution boards intended to be operated by ordinary persons (DBO)	01/01/2021	0007/21
S.I. 2016 No. 1091	EN 61439-3:2012, EN 61439-3:2012 /AC:2019-04	Low-voltage switchgear and controlgear assemblies – Part 3: Distribution boards intended to be operated by ordinary persons (DBO)	01/01/2021	0007/21

Designated standard UKCA RoHS:

S.I. 2012 No. 3033	EN IEC 63000:2018	Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances	01/01/2021	0037/21
-----------------------	-------------------	--	------------	---------