

UKCA DECLARATION OF CONFORMITY No. 22 3552 12 22

We Hager LTD
Hortonwood 50
TELFORD-TF1 7FT-UK

Declare that the product(s)

Designation

Safety Switch ABS / IP65

Type reference(s)

JG Range

Trademark

Hager

is (are) in conformity with the relevant United Kingdom legislation:

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)
 - SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)
 - SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)
-
-

Standard(s) and/or relevant document(s) to which conformity is declared

Standard number + relevant amendments together with the edition dates

EN 60947-3+A1:2012:A2:2015

IEC 60947-3+A1:2012:A2:2015

BS EN IEC 63000:2018

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of Hager LTD

Name of signatory

Ian Ellis

Function of signatory

Certification Manager (Enclosure Systems)

Place and date of issue

Telford, UK 01/12/2022

Signature

Ian Ellis

UKCA DECLARATION OF CONFORMITY

No. 22_3552_12_22

Type references

Product Reference	Product Description
JG416DC	12A 500V DC-21B IP65 Isolator switch
JG425DC	16A 500V DC-21B IP65 Isolator switch
JG440DC	20A 500V DC-21B IP65 Isolator switch
JG10A	1 Normaly Open + 1 Normally Closed Aux Contact 16-80A
JG20A	2 Normaly Open + 2 Normally Closed Aux Contact 16-80A

UKCA DECLARATION OF CONFORMITY

No. 22_3552_12_22

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

Evidences approved by: Site:	Engineering Quality / Certification Telford
Only designated standards published on GOV.UK (https://www.gov.uk/guidance/designated-standards) are used: Scope and classification fully covers the product (case 1 of Hager Group risk analysis): Comments :	Yes EN 60947-3 IEC 60947-3 Yes
Hager Group risk analysis: (Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document DMS034433 - Hager Group risk analysis)	DMS034433 followed using case 1 of Hager Group method: Designated Standard Used
Certificate(s) / test report(s):	MDC_KATKO_JG_2021 CB PL 2 0577/A2 CB PL 2 0578/A2 CB PL 2 0579/A2
Mark approval(s):	None
Product documentation :	See Hager Website
Comments:	None

UKCA DECLARATION OF CONFORMITY

No. 22_3552_12_22

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

Designated Standards

Designated standard UKCA Electromagnetic Compatibility Regulations 2016:

S.I. 2016 No. 1091	EN 60947- 3:2009/A1:2012	Low-voltage switchgear and controlgear - Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units	01/01/2021	0007/21
-----------------------	-----------------------------	---	------------	---------

Designated standard UKCA Electrical Equipment (Safety) Regulations 2016:

S.I. 2016 No. 1101	EN 60947- 3:2009/A1:2012	Low-voltage switchgear and controlgear - Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units	01/01/2021	0009/21
-----------------------	-----------------------------	---	------------	---------

Designated standard UKCA RoHS:

S.I. 2012 No. 3033	EN IEC 63000:2018	Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances	01/01/2021	0037/21
-----------------------	-------------------	--	------------	---------