


**i** (GB) For the tripping times verification tests, in an electrical installation, Hager certifies that the RCDs, of the Hager brand, conforming to standards EN 61008-2-1, EN 61009-2-1, trip under a current of  $5 \cdot I_{\Delta n}$  in accordance with the times imposed in table 41.1 of standard DIN VDE 0100-410 (VDE 0100-410) 2018-10.

## Safety switch (RCCB's) 25 - 40 - 63A






### Please note the following

- 1 - The current rating per pole of the RCCB must not be exceeded by the maximum demand of the protected circuits; refer to clause 1.6.3 "Maximum Demand" in AS/NZS 3000: 2007.
- 2 - If RCCB trips OFF after installation, locate and repair faulty appliances (cumulative leakage from a number of appliances may exceed the RCCB tripping current, causing RCCB to trip OFF).
- 3 - The "main neutral" and "main earth" should be checked to ensure good connection.
- 4 - If RCCB trips intermittently will not reset, or test button will not work, check for low insulation resistance between neutral & earth wiring.






### Electrical connection 4 poles.






Back-up protection chart with MCB's or fuses.

- Refer to Hager general catalog.
- Refer to Hager website.




Single phase connection.



Three phase connection.



RCCB 2P-4P: easy device removal with the DIN rail clip.



**Protection against dust**

In case of work activities nearby, make sure that the electrical installation is protected against dust if the enclosure is not IP5x.

**Auxiliary possibilities.**

CZ001

MZ203... + CZ001  
MZ206

**Locking device for handle MZN175.**

Ø 3,5/  
6 max.