



Ref. Certif. No.

AT 4772

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Low-voltage switchgear and controlgear assembly (PSC)

Name and address of the applicant

Hager Industrie AG
Sedelstrasse 2,
6021 Emmenbrücke, Switzerland

Name and address of the manufacturer

Hager Industrie AG
Sedelstrasse 2,
6021 Emmenbrücke, Switzerland

Name and address of the factory

Hager Industrie AG
Sedelstrasse 2,
6021 Emmenbrücke, Switzerland

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

AC 400 - 690 V, 63 A / 160 A / 250 A,
50-60 Hz, 3P, N, PE

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

--

Model / Type Ref.

uniway

Additional information (if necessary may also be reported on page 2)

--

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61439-2:2011

As shown in the Test Report Ref. No. which forms part of this Certificate

SGP-20863/Hager uniway/CB

This CB Test Certificate is issued by the National Certification Body



Österreichischer Verband für Elektrotechnik
OVE Certification
Kahlenberger Str. 2A, 1190 Wien, Austria



T. Neumayer
Digitally signed by T. Neumayer
Email=t.neumayer@ove.at
Signature: Dipl.-Ing. T. Neumayer

Date: 2022-06-20