

**UKCA DECLARATION OF CONFORMITY No.**

**We** Hager LTD  
Hortonwood 50  
TELFORD-TF1 7FT-UK

**Declare that the product(s)**

**Designation**

20A Double Pole Switch Isolation

**Type reference(s)**

WMDP Range

**Trademark**

Hager

**is (are) in conformity with the relevant United Kingdom legislation:**

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)
- SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)
- SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)
- .....
- .....

**Standard(s) and/or relevant document(s) to which conformity is declared**

*Standard number + relevant amendments together with the edition dates*

**BS EN 60669-1:2017**

**BS EN 60669-2-4:2004**

**BS EN IEC 63000:2018**

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

**This declaration of conformity is issued under the sole responsibility of the manufacturer.**

**On behalf of Hager LTD**

**Name of signatory**

Eddie Li

**Function of signatory**

Lab Manager - Group Quality & Environment

**Place and date of issue**

Huizhou, CN 18/05/2023

**Signature**



2023/05/18

## UKCA DECLARATION OF CONFORMITY

No. UKCA 23.3621.05.23

### Type references

Product Reference	Product Description
WMDP84FOI	20A DP Switch Isolation & Flex Outlet
WMDP84FONI	20A DP Switch Isolation LED & Flex Out
WMDP84I	20A DP Switch Isolation
WMDP84NGI	20A DP Switch Isolation & LED
WMDP84NI	20A DP Switch Isolation & LED
WMDP85FONI	20A DP Switch Isolation LED & Flex Out
WMDP85NI	20A DP Switch Isolation & LED

## UKCA DECLARATION OF CONFORMITY

No. UKCA 23.3621.05.23

### Evidence(s)

Documents listed below have been developed to assure that all essential requirements of applied directive(s) are fulfilled:

If the product is not in the scope of Radio Equipment directive, fulfil table 1a, if yes fulfil table.

Table 1a Risk Assessment for <b>Equipment without Radio</b>		Applicable: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Only designated standards published on GOV.UK ( <a href="https://www.gov.uk/guidance/designated-standards">https://www.gov.uk/guidance/designated-standards</a> ) are used:	Yes BS EN 60669-1:2017 BS EN 60669-2-4:2004		
Scope and classification fully covers the product (case 1 of Hager Group risk analysis) :	Yes		
Comments :	Designated After 2016		
Hager Group risk analysis: Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document <u>DMS034433</u> - Hager Group risk analysis)	DMS034433 followed using case 1 of Hager Group method: Designated Standard Used		

Table 1b Risk Assessment for <b>Radio equipment</b>		Applicable: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Hager Group risk assessment: Fill document DMS063155			

### Evidence(s) / Evidence(s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant directives

Certificate(s) / test report(s):	Eurofins Test Certificate C22 56182 Rev1 DP 20A Eurofins Test Report 56182 Rev1 DP 20A
Mark approval(s):	None
Product documentation :	See Hager Website
Comments:	None

#### Signature (technical design)

##### Name of signatory

John Lee

##### Place and date of issue

Huizhou, CN 18/05/2023

##### Function of signatory

Business Development Manager

##### Signature

## UKCA DECLARATION OF CONFORMITY

No. UKCA 23.3621.05.23

### Designated Standards

Designated standard UKCA Electrical Equipment (Safety) Regulations 2016:

S.I. 2016 No. 1101	EN 60669-1:2018	Switches for household and similar fixed electrical installations - Part 1: General requirements	01/01/2021	0009/21
S.I. 2016 No. 1101	EN 60669-2-4:2005	Switches for household and similar fixed electrical installations - Part 2-4: Particular requirements - Isolating switches	01/01/2021	0009/21

Designated standard UKCA Electromagnetic Compatibility Regulations 2016:

S.I. 2016 No. 1101	EN 60669-1:2018	Switches for household and similar fixed electrical installations - Part 1: General requirements	01/01/2021	0007/21
-----------------------	-----------------	--	------------	---------

Designated standard UKCA RoHS:

S.I. 2012 No. 3033	EN IEC 63000:2018	Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances	01/01/2021	0037/21
-----------------------	-------------------	--	------------	---------