

EU Declaration of Conformity No. 26.1870.02.26

We **Hager Electro SAS**
BP3
67215 OBERNAI CEDEX - FRANCE

declare that the product(s)
designation

Disjoncteur boîtier moulé H400 ELE
MCCB H400 ELE

type reference(s)

HED400U_HND250H_HND400H_HED250H_HED400H
HED401U_HND251H_HND401H_HED251H_HED401H
HED401G_HED400G_HED401F_HNG101U

trademark

Hager

is (are) in conformity with the relevant Union harmonization legislation:

- Low Voltage Directive (LVD) No. 2014/35/EU
- Electromagnetic Compatibility Directive (EMCD) No. 2014/30/EU
- Directive on the Restriction of the use of certain Hazardous Substances (RoHS) No. 2011/65/EU amended by No. 2015/863/EU
- Packaging and Packaging Waste Regulation (PPWR) No. 2025/40/EU

.....

.....

Standard number + relevant amendments together with the edition dates and/or relevant document(s)

EN 60947-2 : 2017-10 + A1 : 2020-02
EN 63000: 2018-12

If applicable, mention here for radio products, the data about notified body. See RED directive - Annex VI - point 7

We additionally confirm compliance with the EU Directives & Regulations, which are not linked to CE marking (if applicable).
See document DMS103207 'General EU Declaration of Conformity'.

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of **Hager Electro SAS - BP3 - 67215 OBERNAI CEDEX - FRANCE**

Name of signatory

Eric BOVIN

Function of signatory

Certification Mandatee

Place and date of issue

Obernai, 15th June 2026

Signature



EU DECLARATION OF CONFORMITY

No. 26.1870.02.26

Type References:

Références	Description
HED400U	Disjoncteur H400 3 poles 400A Icu/Ics= 70/50kA LSI
HND250H	Disjoncteur H400 3 poles 250A Icu/Ics= 50/50kA LSI
HND400H	Disjoncteur H400 3 poles 400A Icu/Ics= 50/50kA LSI
HED250H	Disjoncteur H400 3 poles 250A Icu/Ics= 70/50kA LSI
HED400H	Disjoncteur H400 3 poles 400A Icu/Ics= 70/50kA LSI
HED401U	Disjoncteur H400 4 poles 400A Icu/Ics= 70/50kA LSI
HND251H	Disjoncteur H400 4 poles 250A Icu/Ics= 50/50kA LSI
HND401H	Disjoncteur H400 4 poles 400A Icu/Ics= 50/50kA LSI
HED251H	Disjoncteur H400 4 poles 250A Icu/Ics= 70/50kA LSI
HED401H	Disjoncteur H400 4 poles 400A Icu/Ics= 70/50kA LSI
HED401G	Disjoncteur H400 4 poles 400A plug in Icu/Ics= 70/50kA LSI
HED400G	Disjoncteur H400 3 poles 400A plug in Icu/Ics= 70/50kA LSI
HED401F	Disjoncteur H400 4 poles 400A Draw out Icu/Ics= 70/50kA LSI

EU DECLARATION OF CONFORMITY

NO. 26.1870.02.26

Evidence(s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant directives:

Conformity report / evidence:	CB test certificate No. NL-64834 and Test report No. 2243599.61 Certificate No. KRC 5917-1c Certificate No. KRC 15358f Supplier Compliance Certificate KRC 15235
Product documentation:	See Hager website
Comments:	None

Signature (technical design)

Name of signatory

Oliver PRADOURA

Function of signatory

Product Portfolio Director

Place and date of issue

Obernai, 15th June 2026

Signature

