

EU Declaration of Conformity No. 26.1872.02.26

We **Hager Electro SAS**
BP3
67215 OBERNAI CEDEX - FRANCE

declare that the product(s)
designation

Disjoncteur boîtier moulé H630 ELE
MCCB H630 ELE

type reference(s)

HND630H, HND630U, HND631H, HND631U, HED630H, HED630U, HED631H,
HED631U

trademark

Hager

is (are) in conformity with the relevant Union harmonization legislation:

- Low Voltage Directive (LVD) No. 2014/35/EU
- Electromagnetic Compatibility Directive (EMCD) No. 2014/30/EU
- Directive on the Restriction of the use of certain Hazardous Substances (RoHS) No. 2011/65/EU amended by No. 2015/863/EU
- Packaging and Packaging Waste Regulation (PPWR) No. 2025/40/EU

.....

.....

Standard number + relevant amendments together with the edition dates and/or relevant document(s)

EN 60947-2 : 2017-10 + A1 : 2020-02
EN 63000: 2018-12

If applicable, mention here for radio products, the data about notified body. See RED directive - Annex VI - point 7

We additionally confirm compliance with the EU Directives & Regulations, which are not linked to CE marking (if applicable).
See document DMS103207 'General EU Declaration of Conformity'.

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of Hager Electro SAS - BP3 - 67215 OBERNAI CEDEX - FRANCE

Name of signatory

Eric BOVIN

Function of signatory

Certification Mandatee

Place and date of issue

Obernai, 15th June 2026

Signature



EU DECLARATION OF CONFORMITY

No. 26.1872.02.26

Type References:

Types References	Description
HND630H	MCCB H630 3 poles 630 A Icu/Ics= 50/50 kA LSI
HND630U	MCCB H630 3 poles 630 A Icu/Ics= 50/50 kA LSI
HND631H	MCCB H630 4 poles 630 A Icu/Ics= 50/50 kA LSI
HND631U	MCCB H630 4 poles 630 A Icu/Ics= 50/50 kA LSI
HED630H	MCCB H630 3 poles 630 A Icu/Ics= 70/50 kA LSI
HED630U	MCCB H630 3 poles 630 A Icu/Ics= 70/50 kA LSI
HED631H	MCCB H630 4 poles 630 A Icu/Ics= 70/50 kA LSI
HED631U	MCCB H630 4 poles 630 A Icu/Ics= 70/50 kA LSI

EU DECLARATION OF CONFORMITY

NO. 26.1872.02.26

Evidence(s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant directives:

Conformity report / evidence:	CB test certificate No. NL-64940 and Test report No. 2243599.63 Certificate No. KRC 5917-1c Certificate No. KRC 15235
Product documentation:	See Hager website
Comments:	None

Signature (technical design)

Name of signatory

Oliver PRADOURA

Function of signatory

Product Portfolio Director

Place and date of issue

Obernai, 15th June 2026

Signature

