

EU Declaration of Conformity No. 26.1873.02.26

We **Hager Electro SAS**
BP3
67215 OBERNAI CEDEX - FRANCE

declare that the product(s)
designation

Disjoncteur boîtier moulé H800 ELE
MCCB H800 ELE

type reference(s)

HNE630H_HNE630U_HNE800H_HNE800U_HNE631H_HNE631U_
HEE631G_HEE630H_HEE631H_HEE800G_HNE801H_HNE801U_
HEE800H_HEE800U_HEE801H_HEE801U

trademark

Hager

is (are) in conformity with the relevant Union harmonization legislation:

- Low Voltage Directive (LVD) No. 2014/35/EU
- Electromagnetic Compatibility Directive (EMCD) No. 2014/30/EU
- Directive on the Restriction of the use of certain Hazardous Substances (RoHS) No. 2011/65/EU amended by No. 2015/863/EU
- Packaging and Packaging Waste Regulation (PPWR) No. 2025/40/EU

.....

.....

Standard number + relevant amendments together with the edition dates and/or relevant document(s)

EN 60947-2 : 2017-10 + A1 : 2020-02
EN 63000: 2018-12

If applicable, mention here for radio products, the data about notified body. See RED directive - Annex VI - point 7

We additionally confirm compliance with the EU Directives & Regulations, which are not linked to CE marking (if applicable).
See document DMS103207 'General EU Declaration of Conformity'.

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of **Hager Electro SAS - BP3 - 67215 OBERNAI CEDEX - FRANCE**

Name of signatory

Eric BOVIN

Function of signatory

Certification Mandatee

Place and date of issue

Obernai, 15th June 2026

Signature



EU DECLARATION OF CONFORMITY

No. 26.1873.02.26

Type References:

Type reference	Description
HNE630H	MCCB H800 3 poles 630A Icu/Ics= 50/50kA LSI
HNE630U	MCCB H800 3 poles 630A Icu/Ics= 50/50kA LSI
HNE800H	MCCB H800 3 poles 800A Icu/Ics= 50/50kA LSI
HNE800U	MCCB H800 3 poles 800A Icu/Ics= 50/50kA LSI
HNE631H	MCCB H800 4 poles 630A Icu/Ics= 50/50kA LSI
HNE631U	MCCB H800 4 poles 630A Icu/Ics= 50/50kA LSI
HEE631G	MCCB H800 4 poles 630A Icu/Ics= 70/50kA LSI Plug In
HEE630H	MCCB H800 3 poles 630A Icu/Ics= 70/50kA LSI
HEE631H	MCCB H800 4 poles 630A Icu/Ics= 70/50kA LSI
HEE800G	MCCB H800 3 poles 800A Icu/Ics= 70/50kA LSI Plug In
HNE801H	MCCB H800 4 poles 800A Icu/Ics= 50/50kA LSI
HNE801U	MCCB H800 4 poles 800A Icu/Ics= 50/50kA LSI
HEE800H	MCCB H800 3 poles 800A Icu/Ics= 70/50kA LSI
HEE800U	MCCB H800 3 poles 800A Icu/Ics= 70/50kA LSI
HEE801H	MCCB H800 4 poles 800A Icu/Ics= 70/50kA LSI
HEE801U	MCCB H800 4 poles 800A Icu/Ics= 70/50kA LSI

EU DECLARATION OF CONFORMITY

NO. 26.1873.02.26

Evidence(s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant directives:

Conformity report / evidence:	CB test certificate No. NL-64980 and Test report No. 2243599.64 Certificate No. KRC 5917-1c and KRC 15358f Certificate No. KRC 15235
Product documentation:	See Hager website
Comments:	None

Signature (technical design)

Name of signatory

Oliver PRADOURA

Function of signatory

Product Portfolio Director

Place and date of issue

Obernai, 15th June 2026

Signature

