

EU Declaration of Conformity No. 26.1875.02.26

We **Hager Electro SAS**
BP3
67215 OBERNAI CEDEX - FRANCE

declare that the product(s)
designation

Disjoncteur boîtier moulé H1000 ELE
MCCB H1000 ELE

type reference(s)

HEE970H_HEE970U_HEE971H_HEE971U_HNE970H
HNE970U_HNE971H_HNE971U_HNE700U

trademark

Hager

is (are) in conformity with the relevant Union harmonization legislation:

- Low Voltage Directive (LVD) No. 2014/35/EU
- Electromagnetic Compatibility Directive (EMCD) No. 2014/30/EU
- Directive on the Restriction of the use of certain Hazardous Substances (RoHS) No. 2011/65/EU amended by No. 2015/863/EU
- Packaging and Packaging Waste Regulation (PPWR) No. 2025/40/EU

.....

.....

Standard number + relevant amendments together with the edition dates and/or relevant document(s)

EN 60947-2 : 2017-10 + A1 : 2020-02
EN 63000: 2018-12

If applicable, mention here for radio products, the data about notified body. See RED directive - Annex VI - point 7

We additionally confirm compliance with the EU Directives & Regulations, which are not linked to CE marking (if applicable).
See document DMS103207 'General EU Declaration of Conformity'.

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of **Hager Electro SAS - BP3 - 67215 OBERNAI CEDEX - FRANCE**

Name of signatory

Eric BOVIN

Function of signatory

Certification Mandatee

Place and date of issue

Obernai, 15th June 2026

Signature



EU DECLARATION OF CONFORMITY

No. 26.1875.02.26

Type References:

Type reference	Description
HEE970H	MCCB H1000 3 poles 1000 A Icu/Ics= 70/50 kA LSI
HEE970U	MCCB H1000 3 poles 1000 A Icu/Ics= 70/50 kA LSI
HEE971H	MCCB H1000 4 poles 1000 A Icu/Ics= 70/50 kA LSI
HEE971U	MCCB H1000 4 poles 1000 A Icu/Ics= 70/50 kA LSI
HNE970H	MCCB H1000 3 poles 1000 A Icu/Ics= 50/50 kA LSI
HNE970U	MCCB H1000 3 poles 1000 A Icu/Ics= 50/50 kA LSI
HNE971H	MCCB H1000 4 poles 1000 A Icu/Ics= 50/50 kA LSI
HNE971U	MCCB H1000 4 poles 1000 A Icu/Ics= 50/50 kA LSI
HNE700U	MCCB H800/1000 3 poles 700 A Icu/Ics= 50/50 kA LSI

EU DECLARATION OF CONFORMITY

NO. 26.1875.02.26

Evidence(s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant directives:

Conformity report / evidence:	CB test certificate No. NL-65146 and Test report No. 2243599.66 Certificate No. KRC 5917-1c Certificate No. KRC 15235
Product documentation:	See Hager website
Comments:	None

Signature (technical design)

Name of signatory

Oliver PRADOURA

Function of signatory

Product Portfolio Director

Place and date of issue

Obernai, 15th June 2026

Signature

