

EU Declaration of Conformity No. 26.1239.02.26

We **Hager Electro SAS**
BP3
67215 OBERNAI CEDEX - FRANCE

declare that the product(s)
designation

**Contact auxiliaire / Déclencheur manque de tension - à émission -
surtension - combiné à manque de tension et surtension**
**Auxiliary contacts / Shunt trip - Undervoltage release / Overvoltage
Release / Combinated Overvoltage & undervoltage Release**

type reference(s)

**MZ201 / MZ202 / MZ221 / MZ203 / MZ204 / MZ210 / MZ205 / MZ206 /
MZ209 / MZ212 / MZ216 / MZ214 / MZ215 / CZ001**

trademark

Hager

is (are) in conformity with the relevant Union harmonization legislation:

- Low Voltage Directive (LVD) No. 2014/35/EU
- Electromagnetic Compatibility Directive (EMCD) No. 2014/30/EU
- Directive on the Restriction of the use of certain Hazardous Substances (RoHS) No. 2011/65/EU amended by No. 2015/863/EU
- Packaging and Packaging Waste Regulation (PPWR) No. 2025/40/EU

.....

.....

Standard number + relevant amendments together with the edition dates and/or relevant document(s)

EN 62019: 1999 + A1: 2003 + A11: 2005 + A12: 2014
EN 50550: 2011-02 + A1: 2014-09
EN 60947-5-1 : 2017-12
EN 60947-2 : 2017-10 + A1 : 2020-02
EN 63000: 2018

If applicable, mention here for radio products, the data about notified body. See RED directive - Annex VI - point 7

We additionally confirm compliance with the EU Directives & Regulations, which are not linked to CE marking (if applicable).
See document DMS103207 'General EU Declaration of Conformity'.

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of **Hager Electro SAS - BP3 - 67215 OBERNAI CEDEX - FRANCE**

Name of signatory

Eric BOVIN

Function of signatory

Certification Mandatee

Place and date of issue

Obernai, 15th June 2026

Signature



EU DECLARATION OF CONFORMITY

No. 26.1239.02.26

Type References:

Références Product Reference	Désignation / Product Description
MZ201	Contacteur auxiliaire / Auxiliary Contact 1O+1F 230V AC
MZ202	Contact signal défaut / Contact Signal Default 1O+1F 230V AC
MZ221	Contact auxiliaire bas niveau / Low Level Auxiliary Contact 1F+1O 5/10mA 12/48V AC/DC
MZ203	Déclencheur à émission / Shunt trip Release 230-415V AC 110-130V DC
MZ204	Déclencheur à émission / Shunt trip Release 24-48V AC 12-48V DC
MZ210	
MZ205	Déclencheur à manque de tension / Undervoltage release 48V DC
MZ206	Déclencheur à manque de tension / Undervoltage release 230V AC
MZ209	Déclencheur à surtension / Overvoltage release 230V AC
MZ212	
MZ216	
MZ214	Déclencheur combiné surtension/manque de tension / Combined Overvoltage/ Undervoltage Release Minimum manque de tension / Min Undervoltage: 60 V AC Maximum manque de tension / Max Undervoltage : 230 V AC Surtension / Overvoltage: 270V AC
MZ215	Déclencheur combiné surtension/manque de tension / Combined Overvoltage/ Undervoltage Release Minimum manque de tension / Min Undervoltage: 65 V AC Maximum manque de tension / Max Undervoltage : 230 V AC Surtension / Overvoltage: 267V AC
CZ001	Contact auxiliaire pour interrupteur différentiel / Auxiliary Contact for RCCB (1NO+1NC) 6A 240V AC

EU DECLARATION OF CONFORMITY

NO. 26.1239.02.26

Evidence(s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant directives:

Conformity report / evidence:	CB test certificate NL_75688 CB test certificate NL_74994 EN 50550 Check List test report MZ214 MZ215 EN 50550 Check List test report MZ216 LB_14_0161 MR 14 0016 VDE license for RCCB Nr 40010710 – 40047956 – 40010738 – 40010770 – 40051393 - 40047947 – 40047952 - 40051600
Product documentation:	See Hager website
Comments:	None

Signature (technical design)

Name of signatory

Francis DIEBOLD

Function of signatory

Engineering Director

Place and date of issue

Obernai, 15th February 2026

Signature

